

PRE-INCIDENT SURVEY 2/20/12.

Building Name: ABHW Concrete Survey #: 51

Street Address: 347 S Wharton Station Rd.

City, State, Zip: _____

Primary Use: Concrete Mixing Co. Construction Type: Wood Frame.

Possible Entry: _____

Possible Occupancy: A.M. 3 P.M. 3

Known Handicapped Personnel: _____

NOTIFY IN CASE OF EMERGENCY

Name: Amanda Williams Name: Denise Hudnell Little Manfred
Phone: 945-1245 Phone: 944-4900 Alligood
974-2815 946-2568 943-5245

BUILDING CONSTRUCTION

Roof Type: Wood Frame Floor Construction: Concrete 1st Floor
Wood 2nd Floor.

Roof Construction: Wood w/Metal

Basement Construction Type: _____ Height of Basement: _____

Number of Stories: 2 Height of Each Story: 10

Length: 24 Width: 24 Height: 24

Attic Area: _____ Size: L _____ X W _____ X H _____

UTILITY TYPES

Gas: T. & C. water Type: T. & C. L.P.

Gas Shut Off Valve Location: @ tank

Electric: Washington State Phase: 1

Panel Location: ground floor west wall

Alarm Location: _____

EXPOSURES

North: _____ FT. West: _____ FT. South: _____ FT. East: _____

Type: _____ Type: _____ Type: _____ Type: _____

Manfred Alligood
945 1730

Kathy Alligood 945-4925
946-5899

Stephanie Alligood 943-1749

SUPPRESSION CRITERIA

Needed Fire Flow: _____ Total Water Supply: _____

Fuel Load: _____ Rate of Flow: _____

HYDRANT LOCATIONS

(1) _____ Flow: _____ Unit: _____

(2) _____ Flow: _____ Unit: _____

(3) _____ Flow: _____ Unit: _____

(4) _____ Flow: _____ Unit: _____

OTHER WATER RESOURCES

(1) _____

(2) _____

(3) _____

SPECIAL RESOURCES

(1) _____

(2) _____

(3) _____

MUTUAL AID

(1) _____ Assignment: _____

(2) _____ Assignment: _____

(3) _____ Assignment: _____

STAGING AREA


Primary: _____

Secondary: _____

MISCELLANEOUS INFORMATION

Sprinkler Connection: _____

Standpipe Connection: _____



© 2012 Google
Imagery © S. Geological Survey

Google earth

feet
meters



ABH16
347 S. Wharton Station Rd.

Diesel

Wooded

46'



Concrete Bldg



1 mile

80'

2

3

4

5

10'

Wooded

12" w
Concrete
walls

Wood
Trussed
Roof
@ 24" c/c
w/ Plywood
Sheathing
with
metal
top

1600 GPM

12'

20'

20'

20'

8'

Office
North

Metal
Bldg
Top
5.5' dia
metal-purifier

Air
Compressor

Storage & Garage

8'

1250 GPM

14'

Structure Name ABHW - Garage & Storage
 Structure Address 347 S Wenden Station Rd

Length	Width	Sq Ft	Sq Root	X 18	X construction type	GPM sum 1	X Occupancy	GPM sum 2
81	41	3321	57.63	1037.31	0.8	829.84	1.15	954.32

Column F
Fire Resistive 0.6
Non-combustible 0.8
Ordinary 1
Wood Frame 1.5

Column H
.75 if Mostly non-combustible contents
.85 if Limited combustibles (apartments, churches, schools, hospitals)
1.0 if Mostly combustible (restaurants, sheds, garages)
1.15 if Free burning contents (post offices, horse stables, feed mills, repair garages, ag storage)
1.25 if Rapid burning (aircraft hangers, tires, flammable liquids, wood working)

Exposure % add	Exposure add GPM	Exposure per side (75% max) Side A	Exposure per side 75% max Side B	Exposure per side 75% max Side C	Exposure per side 75% max Side D	Total GPM with exposures
25%	238.58	0	239	0	0	1193.32
19%	181.32				0	
14%	133.61					
9%	85.89					
75%	715.74	Total A,B,C,D				
	MAX	239		Column J, K, L and M		
				If up to 10 feet add 25% per side		
				If 11 to 30 feet add 19% per side		
				If 31 to 60 feet add 14% per side		
				If 61 to 100 feet add 9% per side		

Round off to nearest 250 GPM for flows less than 2500 GPM the nearest 500 GPM over 2500 GPM

Total GPM with exposures	Add 50% for each floor above ground floor	# of floors above	Total to add for floors above	Sub-total with floors added	If wood shingles on roof add 500 GPM
1250.00	625	0	0.00	1250.00	0
					1250.00

FIRE FLOW NEEDED
GPM
1250.00

Structure Name ABHW - Shop.
 Structure Address 347 S Wharton Station Rd.

Length	Width	Sq Ft	Sq Root	X 18	X construction type	GPM sum 1	X Occupancy	GPM sum 2
80	70	5600	74.83	1347.00	0.8	1077.60	0.75	808.20

Exposure % add	Exposure add GPM	Exposure per side (75% max) Side A	Exposure per side 75% max Side B	Exposure per side 75% max Side C	Exposure per side 75% max Side D	Total GPM with exposures
25%	202.05	0	0	0	202	1010.20
19%	153.56				0	
14%	113.15					
9%	72.74					
75%	605.15	Total A, B, C, D				
	MAX	202				

Round off to nearest 250 GPM for flows less than 2500 GPM, the nearest 500 GPM over 2500 GPM

Column F
 Fire Resistive 0.6
 Non-combustible 0.8
 Ordinary 1
 Wood Frame 1.5

Column H
 .75 if Mostly non-combustible contents
 .85 if Limited combustibles (apartments, churches, schools, hospitals)
 1.0 if Mostly combustible (restaurants, sheds, garages)
 1.15 if Free burning contents (post offices, horse stables, feed mills, repair garages, ag storage)
 1.25 if Rapid burning (aircraft hangers, tires, flammable liquids, wood working)

Total GPM with exposures	Add 50% for each floor above ground floor	Total to add for floors above	Sub-total with floors added	If wood shingles on roof add 500 GPM
1000.00	500	0.00	1000.00	0
				1000.00

FIRE FLOW NEEDED
 GPM
1000.00

Structure Name ABH Concrete - Office
 Structure Address 347 S Wharton Station Rd.

Length	Width	Sq Ft	Sq Root	X 18	X construction type	GPM sum 1	X Occupancy	GPM sum 2
24	24	576	24.00	432.00	1.5	648.00	0.85	550.80

Column F
Fire Resistive 0.6
Non-combustible 0.8
Ordinary 1
Wood Frame 1.5

Column H
.75 if Mostly non-combustible contents .85 if Limited combustibles (apartments, churches, schools, hospitals)
1.0 if Mostly combustible (restaurants, sheds, garages)
1.15 if Free burning contents (post offices, horse stables, feed mills, repair garages, ag storage)
1.25 if Rapid burning (aircraft hangers, tires, flammable liquids, wood working)

Exposure % add	Exposure add GPM	Exposure per side (75% max) Side A	Exposure per side 75% max Side B	Exposure per side 75% max Side C	Exposure per side 75% max Side D	Total GPM with exposures
25%	137.70	0	0	0	0	550.80
19%	104.65					0
14%	77.11					
9%	49.57					
75%	413.10	Total A,B,C,D				
	MAX	0				
			Column J, K, L and M			
			If up to 10 feet add 25% per side			
			If 11 to 30 feet add 19% per side			
			If 31 to 60 feet add 14% per side			
			If 61 to 100 feet add 9% per side			

Round off to nearest 250 GPM for flows less than 2500 GPM the nearest 500 GPM over 2500 GPM

Total GPM with exposures	Add 50% for each floor above ground floor	# of floors above	Total to add for floors above	Sub-total with floors added	If wood shingles on roof add 500 GPM
500.00	250	1	250.00	750.00	0
				750.00	750.00

FIRE FLOW NEEDED
GPM
750.00