

1250 6PM
HANDOUT #17

2/18/12

PRE-INCIDENT SURVEY

Building Name: Mid-Atlantic Hydraulics & Machine Survey #: 41
Street Address: 5324 U.S. 264 West
City, State, Zip: Washington, N.C. 27889
Primary Use: full service repair shop Construction Type: ordinary
Possible Entry: front door (office)
Possible Occupancy: A.M. _____ P.M. _____
Known Handicapped Personnel: _____

NOTIFY IN CASE OF EMERGENCY

Name: _____ Name: _____
Phone: _____ Phone: _____

BUILDING CONSTRUCTION

Roof Type: flat (metal) Floor Construction: concrete
Roof Construction: metal
Basement Construction Type: N/A Height of Basement: N/A
Number of Stories: 1 Height of Each Story: _____
Length: _____ Width: _____ Height: 15'
Attic Area: N/A Size: L _____ X W _____ X H _____

UTILITY TYPES

Gas: LP Tank Type: _____
Gas Shut Off Valve Location: tank
Electric: Washington Utility Phase: 3
Panel Location: _____
Alarm Location: (Seaboard Security System)

EXPOSURES

North: 74 FT. West: _____ FT. South: _____ FT. East: _____
Type: Shop - Wood Frame Type: _____ Type: _____ Type: _____

SUPPRESSION CRITERIA

Needed Fire Flow: _____ Total Water Supply: _____

Fuel Load: _____ Rate of Flow: _____

HYDRANT LOCATIONS

- (1) Across Intersection Flow: 1100 Unit: GPM
- (2) @ 3197 Wharton Station Rd. Flow: 1000 Unit: GPM
- (3) _____ Flow: _____ Unit: _____
- (4) _____ Flow: _____ Unit: _____

OTHER WATER RESOURCES

- (1) _____
- (2) _____
- (3) _____

SPECIAL RESOURCES

- (1) _____
- (2) _____
- (3) _____

MUTUAL AID

- (1) _____ Assignment: _____
- (2) _____ Assignment: _____
- (3) _____ Assignment: _____

STAGING AREA


Primary: _____

Secondary: _____

MISCELLANEOUS INFORMATION

Sprinkler Connection: _____

Standpipe Connection: _____



Structure Name M10 Atlantic Hydraulics & Machine
 Structure Address 5324 US 264 W

Length	Width	Sq Ft	Sq Root	X 18	X construction type	GPM sum 1	X Occupancy	GPM sum 2
233	52.34	12195	110.43	1987.76	0.8	1590.21	0.75	#####

Column F
Fire Resistive 0.6
Non-combustible 0.8
Ordinary 1
Wood Frame 1.5

Column H
.75 If Mostly non-combustible contents
.85 If Limited combustibles (apartments, churches, schools, hospitals)
1.0 If Mostly combustible (restraunts, sheds, garages)
1.15 if Free burning contents (post offices, horse stables, feed mills, repair garages, ag storage)
1.25 if Rapid burning (aircraft hangers, tires, flammable liquids, wood working)

Exposure % add	Exposure add GPM	Exposure per side (75% max) Total Side A	Exposure per side 75% max Side B	Exposure per side 75% max Side C	Exposure per side 75% max Side D	Total GPM with exposures
25%	298.16		0	107		1299.65
19%	226.60					
14%	166.97					
9%	107.34					
75%	894.49	Total A, B, C, D				
MAX	107					

Column J, K, L and M
If up to 10 feet add 25% per side
If 11 to 30 feet add 19% per side
If 31 to 60 feet add 14% per side
If 61 to 100 feet add 9% per side

Round off to nearest 250 GPM for flows less than 2500 GPM. the nearest 500 GPM over 2500 GPM

Total GPM with exposures	Add 50% for each floor above ground floor	# of floors	Total to add for floors above	Sub-total with floors added	If wood shingles on roof add 500 GPM
1250.00	625	0	0.00	1250.00	0 1250.00

FIRE FLOW NEEDED
GPM
1250.00