

PRE-INCIDENT SURVEY

2-18-12

Building Name: The Shutter Factory Survey #: 42
Street Address: 6139 Hwy 264
City, State, Zip: Washington, N.C. 27889
Primary Use: manufacture shutters Construction Type: ordinary
Possible Entry: Front Door (Side A); Side B
Possible Occupancy: 2 to 3 A.M. 8 P.M. 5
Known Handicapped Personnel: _____

NOTIFY IN CASE OF EMERGENCY

Name: Beed Boseman Name: _____
Phone: 974-2795 Phone: _____

BUILDING CONSTRUCTION

Roof Type: metal Floor Construction: concrete
Roof Construction: _____
Basement Construction Type: N/A Height of Basement: N/A
Number of Stories: 1 Height of Each Story: _____
Length: 100' Width: 50' Height: 20'
Attic Area: _____ Size: L _____ X W _____ X H _____

UTILITY TYPES

Gas: _____ Type: _____
Gas Shut Off Valve Location: _____
Electric: Washington Utilities Phase: _____
Panel Location: ~~Rear Side B~~ Side D
Alarm Location: N/A

EXPOSURES

North: _____ FT. West: 60 FT. South: _____ FT. East: _____
Type: _____ Type: metal Type: _____ Type: _____

SUPPRESSION CRITERIA

Needed Fire Flow: _____ Total Water Supply: _____

Fuel Load: _____ Rate of Flow: _____

HYDRANT LOCATIONS

(1) _____ Flow: _____ Unit: _____

(2) _____ Flow: _____ Unit: _____

(3) _____ Flow: _____ Unit: _____

(4) _____ Flow: _____ Unit: _____

OTHER WATER RESOURCES

(1) _____

(2) _____

(3) _____

SPECIAL RESOURCES

(1) _____

(2) _____

(3) _____

MUTUAL AID

(1) _____ Assignment: _____

(2) _____ Assignment: _____

(3) _____ Assignment: _____

STAGING AREA

Primary: _____

Secondary: _____

MISCELLANEOUS INFORMATION


Sprinkler Connection: _____

Standpipe Connection: _____

The Shutter Factory

Shelter w/
2-Air Compresses

⊙ → 250 gal
Gas Cylinder



Hwy 264

Structure Address

Length	Width	Sq Ft	Sq Root	X 18	X construction type	GPM sum 1	X Occupancy	GPM sum 2
100	50	5000	70.71	1272.79	0.8	1018.23	1.25	#####

Exposure % add	Exposure add GPM	Exposure per side (75% max) Total	Exposure per side 75% max Side A	Exposure per side 75% max Side B	Exposure per side 75% max Side C	Exposure per side 75% max Side D	Total GPM with exposures
25%	318.20			0	0	178	1450.79
19%	241.83						
14%	178.19						
9%	114.55						
75%	954.59	Total A B C D					
	MAX		178				
					Column J, K, L and M		
						If up to 10 feet add 25% per side	
						If 11 to 30 feet add 19% per side	
						If 31 to 60 feet add 14% per side	
						If 61 to 100 feet add 9% per side	
							Round off to nearest 250 GPM less than 2500 the nearest over 2500

Column F
Fire Resistive 0.6
Non-combustible 0.8
Ordinary 1
Wood Frame 1.5

Column H
0.75 If Mostly non-combustible contents 0.85 If Limited combustibles (apartments, churches, schools, hospitals) 1.0 If Mostly combustible (restaurants, sheds, garages) 1.15 If Free burning contents (post offices, horse stables, feed mills, repair garages,ag storage) 1.25 If Rapid burning (aircraft hangers, tires, flammable liquids, wood working)

Total GPM with exposures	Add 50% for each floor above ground floor	# of floors above	Total to add for floors above	Sub-total with floors added	If wood shingles on roof add 500 GPM
1500.00	750	0	0.00	1500.00	0

FIRE FLOW NEEDED
GPM
1500.00